

§ 410.94

§ 410.94 Pretreatment standards for existing sources (PSES).

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

§ 410.95 New source performance standards (NSPS).

Any new source subject to this subpart must achieve the following new source performance standards (NSPS):

Pollutant or pollutant property	NSPS	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kg (or pounds per 1,000 lb) of product	
BOD ₅	16.9	8.7
COD	179.3	115.5
TSS	50.9	22.7
Sulfide	0.44	0.22
Phenols	0.22	0.11
Total Chromium	0.22	0.11
pH	(¹)	(¹)

¹ Within the range of 6.0 to 9.0 at all times.
Note: Additional allocations for "commission finishers" are not available to new sources.

§ 410.96 Pretreatment standards for new sources (PSNS).

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

§ 410.97 Effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT). [Reserved]

PART 411—CEMENT MANUFACTURING POINT SOURCE CATEGORY

Subpart A—Nonleaching Subcategory

Sec.

- 411.10 Applicability; description of the non-leaching subcategory.
- 411.11 Specialized definitions.
- 411.12 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

40 CFR Ch. I (7–1–12 Edition)

- 411.13 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable.
- 411.14 Pretreatment standards for existing sources.
- 411.15 Standards of performance for new sources.
- 411.16 Pretreatment standards for new sources.
- 411.17 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.

Subpart B—Leaching Subcategory

- 411.20 Applicability; description of the leaching subcategory.
- 411.21 Specialized definitions.
- 411.22 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.
- 411.23 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable.
- 411.24 Pretreatment standards for existing sources.
- 411.25 Standards of performance for new sources.
- 411.26 Pretreatment standards for new sources.
- 411.27 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the conventional pollutant control technology (BCT).

Subpart C—Materials Storage Piles Runoff Subcategory

- 411.30 Applicability; description of the materials storage piles runoff subcategory.
- 411.31 Specialized definitions.
- 411.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.
- 411.33 [Reserved]
- 411.34 Pretreatment standards for existing sources.
- 411.35 Standards of performance for new sources.
- 411.36 Pretreatment standards for new sources.
- 411.37 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology.